



February 27, 2017

MK5 Manufacturing Ltd.
9186 Hwy 93
PO Box 35041
Midland, Ontario
L4R 4K4

Attention: Mr. Mike Maughan

**RE: MK5 (7" SLAB FOUNDATION) FOR 60FT. X 70FT. AMERICAN BUILDINGS PRE-ENGINEERED STEEL BUILDING FOR ABBOTSFORD, BRITISH COLUMBIA
OUR JOB NO. 160413**

Dear Mr. Maughan:

Following your instructions, we have completed our review by random visual sampling of the MK5 (7" slab foundation) for the American Buildings pre-engineered steel building for Abbotsford, British Columbia. The applicable documentation for this installation consists of our Drawing No. 160413-S1 Rev.1). At the time of our review, the forms and reinforcing steel had been installed in preparation for pouring the concrete slab. We expect that the perimeter insulation will be installed around the slab perimeter for this heated building at a later date.

Based on the terms of this report, we are satisfied that the installation of formwork and reinforcement for the 7" thick floating slab building foundation have been completed and that it complies with out structural design intent, drawing details, applicable code regulations, and good constructions practise.



DJL/mm

Yours very truly,
A-D Engineering Group Ltd.

David Lehman, P.Eng
Consulting Engineer